

# A CASE HISTORY

## *ENDURA-FLEX*® 1988



### MARIN MUNICIPAL WATER DISTRICT SAUSALITO POTABLE WATER TANK

**Polyurethane Type:** Endura-Flex® 1988, Expanded

UL, ANSI/Standard 61

Approved Lining

Film Thickness: 60 mils TDFT

**Vessel:**

Riveted Steel, Potable Water Tank

**Applicator:**

Jeffco Painting

Contact: Jim Tank

Phone: 707-562-1900

**Date of Application:** March, 2007